

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150114-E194191  
**Report Reference** E194191-20141022  
**Issue Date** 2015-JANUARY-14

**Issued to:** ABB SPA - ABB SACE DIVISION  
VIA PESCARIA 5  
24123 BERGAMO BG ITALY

**This is to certify that  
representative samples of**

LOW-VOLTAGE AC POWER CIRCUIT BREAKERS  
Power circuit breakers - 2500A-3200A Frame - Types  
SACE E4.2S, E4.2H, E4.2V  
Molded case circuit breakers frames - 2500A-3200A Frame  
- Types SACE E4.2S, E4.2H, E4.2V

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL1066, Low-Voltage AC and DC Power Circuit Breakers  
Used in Enclosures  
NEMA C37.50, Low Voltage AC Power Circuit Breakers  
Used in Enclosures - Test Procedures  
IEEE C37.13, Low-Voltage AC Power Circuit Breakers  
Used in Enclosures  
IEEE C37.13A, Low-Voltage AC Power Circuit Breakers  
Used in Enclosures — Amendment 1: Increase of Voltages  
to 1000 V AC and Below  
IEEE C37.17, Trip Systems for Low-Voltage (1000 V and  
Below) AC and General Purpose (1500 V and Below) DC  
Power Circuit Breakers

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

