

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 080100-E194191

Page 1 of 1

ISSUE DATE: August 1, 2000

Issued to: ABB SACE LOW VOLTAGE SpA
Via Baioni 35
24123 Bergamo, Italy

Report Reference: E194191/E194424/E194425

This is to Certify that
representative samples of:


Breaker	Poles	Amperes	Volts
E1	3	800-1200	600
E2	3-4	1200-1600	600
E3	3-4	1200-2500	600
E4	3-4	3200-3600	600
E6	3-4	4000-5000	600

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1066 - Low Voltage AC and DC Power Circuit Breakers
Used in Enclosures

Additional Information: E194191 - Low Voltage Power Breakers (PAQX)
E194424 - Fixed Parts Adapters (PAQQ)
E194425 - Accessories (PAQX)

Only those products bearing the UL Classification Marking should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Marking includes: UL in a circle symbol  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and the product category name (product identity) as indicated in the appropriate UL Directory.

LOOK FOR THE UL CLASSIFICATION MARKING ON THE PRODUCT

Engineer:


A. TITOLO

Underwriters Laboratories Inc.

Review Engineer:


S. PORCILLO

Underwriters Laboratories Inc.